

PHARMACOPOEIAL DISCUSSION GROUP

CORRECTION

CODE: G-01


NAME: ANALYTICAL SIEVING

(Correction of the sign-off document Rev. 1 signed on May 8, 2007)

Item to be corrected:

- 1) The sieve diameters listed in harmonized document were changed from "200 mm" to "200 mm or 203 mm (8-inch)" and from "76 mm" to "75 mm or 76 mm (3-inch)" respectively.
- 2) Some editorial changes were made to the "TEST SIEVES" section of the text.
- 3) USP adds the following note to the section of Test Specimen as USP local text: "The 8-inch (203 mm) frame diameter sieve is equivalent to the 200 mm frame diameter sieve. The 3-inch (76 mm) frame diameter sieve is equivalent to the 75 mm frame diameter sieve."


European Pharmacopoeia

Signature	Name	Date
	Petra Doer	28/10/2021

Japanese Pharmacopoeia

Signature	Name	Date
 for Y. Yoshida	Yukihiro Goda	15 Nov, 2021

United States Pharmacopeia

Signature	Name	Date
	Kevin Moore	9-Nov-2021

1
2
3
4
5

**PARTICLE SIZE
DISTRIBUTION ESTIMATION
BY ANALYTICAL SIEVING**

6 Sieving is one of the oldest methods of classifying powders and granules by particle size
7 distribution. When using a woven sieve cloth, the sieving will essentially sort the particles by their
8 intermediate size dimension (i.e., breadth or width). Mechanical sieving is most suitable where
9 the majority of the particles are larger than about 75 μm . For smaller particles, the light weight provides
10 insufficient force during sieving to overcome the surface forces of cohesion and adhesion that cause
11 the particles to stick to each other and to the sieve, and thus cause particles that would be expected to
12 pass through the sieve to be retained. For such materials other means of agitation such as air-jet sieving
13 or sonic sifting may be more appropriate. Nevertheless, sieving can sometimes be used for some
14 powders or granules having median particle sizes smaller than 75 μm where the method can be
15 validated. In pharmaceutical terms, sieving is usually the method of choice for classification of
16 the coarser grades of single powders or granules. It is a particularly attractive method in that powders
17 and granules are classified only on the basis of particle size, and in most cases the analysis can be
18 carried out in the dry state.

19 Among the limitations of the sieving method are the need for an appreciable amount of sample
20 (normally at least 25 g, depending on the density of the powder or granule, and the diameter of test
21 sieves) and difficulty in sieving oily or other cohesive powders or granules that tend to clog the sieve
22 openings. The method is essentially a two-dimensional estimate of size because passage through
23 the sieve aperture is frequently more dependent on maximum width and thickness than on length.

24 This method is intended for estimation of the total particle size distribution of a single material.
25 It is not intended for determination of the proportion of particles passing or retained on one or two
26 sieves.

27 Estimate the particle size distribution as described under *Dry Sieving Method*, unless otherwise
28 specified in the individual monograph. Where difficulty is experienced in reaching the endpoint (i.e.,
29 material does not readily pass through the sieves) or when it is necessary to use the finer end of
30 the sieving range (below 75 μm), serious consideration should be given to the use of an alternative
31 particle-sizing method.

32 Sieving should be carried out under conditions that do not cause the test sample to gain or lose
33 moisture. The relative humidity of the environment in which the sieving is carried out should be
34 controlled to prevent moisture uptake or loss by the sample. In the absence of evidence to the contrary,
35 analytical test sieving is normally carried at ambient humidity. Any special conditions that apply to a
36 particular material should be detailed in the individual monograph.

37 **Principles of Analytical Sieving**—Analytical test sieves are constructed from a woven-wire
38 mesh, which is of simple weave that is assumed to give nearly square apertures and is sealed into the
39 base of an open cylindrical container. The basic analytical method involves stacking the sieves on top
40 of one another in ascending degrees of coarseness, and then placing the test powder on the top sieve.

41 The nest of sieves is subjected to a standardized period of agitation, and then the weight of
42 material retained on each sieve is accurately determined. The test gives the weight percentage of
43 powder in each sieve size range.

44 This sieving process for estimating the particle size distribution of a single pharmaceutical
45 powder is generally intended for use where at least 80% of the particles are larger than 75 μm . The size
46 parameter involved in determining particle size distribution by analytical sieving is the length of
47 the side of the minimum square aperture through which the particle will pass.
48

49 **TEST SIEVES**

50

51

52

53

54

55

56

57

Test sieves suitable for pharmacopeial tests conform to the current edition of International Organisation for Standardization (ISO) ISO 3310 - 1 specification; Test sieves – Technical requirements and testing – Part 1: Test sieves of metal wire cloth. Unless otherwise specified in the monograph, use those ISO sieves listed in Table 1 as recommended in the particular region.

Table 1. Sizes of Standard Sieve Series in Range of Interest

Principal sizes	ISO Nominal Aperture		US Sieve No.	Recommended USP Sieves (microns)	European Sieve No.	Japan Sieve No.
	Supplementary sizes	R 40/3				
R 20/3	R20	R 40/3				
11.20 mm	11.20 mm 10.00 mm	11.20 mm 9.50 mm			11200	
8.00 mm	9.00 mm 8.00 mm 7.10 mm	8.00 mm 6.70 mm				
5.60 mm	6.30 mm 5.60 mm 5.00 mm	5.60 mm 4.75 mm			5600	3.5 4
4.00 mm	4.50 mm 4.00 mm 3.55 mm	4.00 mm 3.35 mm	5 6	4000	4000	4.7 5.5
2.80 mm	3.15 mm 2.80 mm 2.50 mm	2.80 mm 2.36 mm	7 8	2800	2800	6.5 7.5
2.00 mm	2.24 mm 2.00 mm 1.80 mm	2.00 mm 1.70 mm	10 12	2000	2000	8.6 10
1.40 mm	1.60 mm 1.40 mm 1.25 mm	1.40 mm 1.18 mm	14 16	1400	1400	12 14
1.00 mm	1.12 mm 1.00 mm 900 µm	1.00 mm 850 µm	18 20	1000	1000	16 18
710 µm	800 µm 710 µm 630 µm	710 µm 600 µm	25 30	710	710	22 26
500 µm	560 µm 500 µm 450 µm	500 µm 425 µm	35 40	500	500	30 36
355 µm	400 µm 355 µm 315 µm	355 µm 300 µm	45 50	355	355	42 50
250 µm	280 µm 250 µm 224 µm	250 µm 212 µm	60 70	250	250	60 70
180 µm	200 µm 180 µm 160 µm	180 µm 150 µm	80 100	180	180	83 100
125 µm	140 µm 125 µm 112 µm	125 µm 106 µm	120 140	125	125	119 140

90 μm	100 μm 90 μm 80 μm	90 μm	170	90	90	166
		75 μm	200			200
63 μm	71 μm 63 μm 56 μm	63 μm	230	63	63	235
		53 μm	270			282
45 μm	50 μm 45 μm 40 μm	45 μm	325	45	45	330
		38 μm			38	391

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

Sieves are selected to cover the entire range of particle sizes present in the test specimen. A nest of sieves having a $\sqrt{2}$ progression of the area of the sieve openings is recommended. The nest of sieves is assembled with the coarsest screen at the top and the finest at the bottom. Use micrometers or millimeters in denoting test sieve openings. [NOTE—Sieve numbers are provided in the table for conversion purposes only.] Test sieves are made from stainless steel or, less preferably, from brass or other suitable non-reactive wire.

Calibration and recalibration of test sieves is in accordance with the most current edition of ISO 3310 - 1. Sieves should be carefully examined for gross distortions and fractures, especially at their screen frame joints, before use. Sieves may be calibrated optically to estimate the average opening size, and opening variability, of the sieve mesh. Alternatively, for the evaluation of the effective opening of test sieves in the size range of 212 to 850 μm , Standard Glass Spheres are available. Unless otherwise specified in the individual monograph, perform the sieve analysis at controlled room temperature and at ambient relative humidity.

Cleaning Test Sieves—Ideally, test sieves should be cleaned using only an air jet or a liquid stream. If some apertures remain blocked by test particles, careful gentle brushing may be used as a last resort.

Test Specimen—If the test specimen weight is not given in the monograph for a particular material, use a test specimen having a weight between 25 and 100 g, depending on the bulk density of the material, and test sieves having a diameter of 200 mm or 203 mm (8-inch). For sieves of 75 mm or 76 mm (3-inch) diameter the amount of material that can be accommodated is approximately $1/7^{\text{th}}$ of which can be accommodated on a 200 mm or 203 mm sieve. Determine the most appropriate weight for a given material by test sieving accurately weighed specimens of different weights, such as 25, 50, and 100 g, for the same time period on a mechanical shaker. [NOTE—If the test results are similar for the 25-g and 50-g specimens, but the 100-g specimen shows a lower percentage through the finest sieve, the 100-g specimen size is too large.] Where only a specimen of 10 to 25 g is available, smaller diameter test sieves conforming to the same mesh specifications may be substituted, but the endpoint must be re-determined. The use of test samples having a smaller mass (e.g. down to 5 g) may be needed. For materials with low apparent particle density, or for materials mainly comprising particles with a highly iso-diametrical shape, specimen weights below 5 g for a 200 mm or 203 mm sieve may be necessary to avoid excessive blocking of the sieve. During validation of a particular sieve analysis method, it is expected that the problem of sieve blocking will have been addressed.

If the test material is prone to picking up or losing significant amounts of water with varying humidity, the test must be carried out in an appropriately controlled environment. Similarly, if the test material is known to develop an electrostatic charge, careful observation must be made to ensure that such charging is not influencing the analysis. An antistatic agent, such as colloidal silicon dioxide and/or aluminum oxide, may be added at a 0.5 percent (m/m) level to minimize this effect. If both of the above effects cannot be eliminated, an alternative particle-sizing technique must be selected.

Agitation Methods—Several different sieve and powder agitation devices are commercially available, all of which may be used to perform sieve analyses. However, the different methods of agitation may give different results for sieve analyses and endpoint determinations because of the different types and magnitude of the forces acting on the individual particles under test. Methods using mechanical agitation or electromagnetic agitation, and that can induce either a vertical oscillation

101 or a horizontal circular motion, or tapping or a combination of both tapping and horizontal circular
102 motion are available. Entrainment of the particles in an air stream may also be used. The results must
103 indicate which agitation method was used and the agitation parameters used (if they can be varied),
104 since changes in the agitation conditions will give different results for the sieve analysis and endpoint
105 determinations, and may be sufficiently different to give a failing result under some circumstances.

106
107 **Endpoint Determination**—The test sieving analysis is complete when the weight on any of
108 the test sieves does not change by more than 5% or 0.1 g (10% in the case of 75 mm or 76 mm sieves)
109 of the previous weight on that sieve. If less than 5% of the total specimen weight is present on a given
110 sieve, the endpoint for that sieve is increased to a weight change of not more than 20% of the previous
111 weight on that sieve.

112 If more than 50% of the total specimen weight is found on any one sieve, unless this is indicated
113 in the monograph, the test should be repeated, but with the addition to the sieve nest of a more coarse
114 sieve intermediate between that carrying the excessive weight and the next coarsest sieve in the original
115 nest, i.e., addition of the ISO series sieve omitted from the nest of sieves.

117 SIEVING METHODS

119 Mechanical agitation

120 **Dry Sieving Method**—Tare each test sieve to the nearest 0.1 g. Place an accurately weighed
121 quantity of test specimen on the top (coarsest) sieve, and replace the lid. Agitate the nest of sieves for
122 5 minutes. Then carefully remove each from the nest without loss of material. Reweigh each sieve,
123 and determine the weight of material on each sieve. Determine the weight of material in the collecting
124 pan in a similar manner. Reassemble the nest of sieves, and agitate for 5 minutes. Remove and weigh
125 each sieve as previously described. Repeat these steps until the endpoint criteria are met (see *Endpoint*
126 *Determination* under *Test Sieves*). Upon completion of the analysis, reconcile the weights of material.
127 Total losses must not exceed 5% of the weight of the original test specimen.

128 Repeat the analysis with a fresh specimen, but using a single sieving time equal to that of the
129 combined times used above. Confirm that this sieving time conforms to the requirements for endpoint
130 determination. When this endpoint has been validated for a specific material, then a single fixed time
131 of sieving may be used for future analyses, providing the particle size distribution falls within normal
132 variation.

133 If there is evidence that the particles retained on any sieve are aggregates rather than single
134 particles, the use of mechanical dry sieving is unlikely to give good reproducibility, a different particle
135 size analysis method should be used.

137 Air Entrainment Methods

138 **Air Jet and Sonic Sifter Sieving** —Different types of commercial equipment that use a
139 moving air current are available for sieving. A system that uses a single sieve at a time is referred to
140 as *air jet* sieving. It uses the same general sieving methodology as that described under the *Dry Sieving*
141 *Method*, but with a standardized air jet replacing the normal agitation mechanism. It requires
142 sequential analyses on individual sieves starting with the finest sieve to obtain a particle size
143 distribution. Air jet sieving often includes the use of finer test sieves than used in ordinary dry sieving.
144 This technique is more suitable where only oversize or undersize fractions are needed.

145 In the *sonic sifting* method, a nest of sieves is used, and the test specimen is carried in a vertically
146 oscillating column of air that lifts the specimen and then carries it back against the mesh openings at a
147 given number of pulses per minute. It may be necessary to lower the sample amount to 5 g, when
148 sonic sifting is employed.

149 The air jet sieving and sonic sieving methods may be useful for powders or granules when
150 mechanical sieving techniques are incapable of giving a meaningful analysis.

151 These methods are highly dependent upon proper dispersion of the powder in the air current.
152 This requirement may be hard to achieve if the method is used at the lower end of the sieving range
153 (i.e., below 75 μm), when the particles tend to be more cohesive, and especially if there is any tendency
154 for the material to develop an electrostatic charge. For the above reasons endpoint determination is
155 particularly critical, and it is very important to confirm that the oversize material comprises single
156 particles and is not composed of aggregates.

157

158 INTERPRETATION

159

160 The raw data must include the weight of test specimen, the total sieving time, and the precise
161 sieving methodology and the set values for any variable parameters, in addition to the weights retained
162 on the individual sieves and in the pan. It may be convenient to convert the raw data into a cumulative
163 weight distribution, and if it is desired to express the distribution in terms of a cumulative weight
164 undersize, the range of sieves used should include a sieve through which all the material passes. If
165 there is evidence on any of the test sieves that the material remaining on it is composed of aggregates
166 formed during the sieving process, the analysis is invalid.

167

168